



Code of Federal Regulations

U.S Coast Guard Fire Test #183.590

(min. 648 degrees C within 1 inch of component for 2.5 minutes)

PASS - Ball Valve fully functional (with no leaks)

